

CLASSIFICATION REPORT FOR THE FIRE REACTION OF A MATERIAL

As per the Order of 21 November 2002 amended relative to fire reaction
of construction and fitting products
Pilot laboratory approved by the Ministry of Interior (Order of 05/02/59 amended)
Seule la version française fait foi
Only the French version is legally acceptable

No. RA15-0149

Valid 5 years from June 19th, 2015

Material presented by: SARECO GmbH
Birkhof 14, Postfach 7024
49479 IBBENBUREN
GERMANY

Trademark: DUHOSPAN FR. MELAMINFACED CHIPBOARD

Short description:

Panels consisting of a substrate made of fire-retarded during production wood particleboard referenced "SPANO ANTIVLAM" coated by lamination (melamine glue) on the visible side with a decorative melamine paper.

The back side is coated with a similar counterbalancing melamine paper.

Nominal thicknesses of the wood particleboards: 12 and 19 mm.

Nominal density of the wood particleboard: 745 kg/m³.

Nominal weights per unit area of the decorative melamine paper: 80 and 90 g/m².

Overall measured weights per unit area: about 9 and 13 kg/m².

Colours: various.

Nature of the test: Test by radiation

Classification valid for any application for which the product is not subject to CE marking:

M1 valid for a 12 mm thickness

M2 valid for a 19 mm thickness

Classification durability (Appendix 2 – Paragraph 5): Non-limited a priori.
considering the criteria resulting from the tests described in the test report No. RA15-0149 appended.

This report approves only the characteristics of the sample subject to tests and carries no presumption on the characteristics of similar products. Therefore it does not make up a certification of products in the meaning of articles L 115-27 to L 115-33 and R 115-1 to R 115-3 of the consumer code.

Modification of the short description.

The document RA15-0149 dated August 04th, 2015 cancels and replaces the document RA15-0149 dated June 19th, 2015.

Champs-sur-Marne, August 04th, 2015

The Head of Reaction to Fire
Laboratory



Nicolas ROURE

Only complete reproductions of this classification report or the entire classification report and appended test report are authorized.

CENTRE SCIENTIFIQUE ET TECHNIQUE DU BATIMENT

SIÈGE SOCIAL > 84 AVENUE JEAN JAURÈS | CHAMPS-SUR-MARNE | 77447 MARNE-LA-VALLÉE CEDEX 2

TÉL. (33) 01 64 68 84 12 | FAX. (33) 01 64 68 84 79 | www.cstb.fr

MARNE-LA-VALLÉE | PARIS | GRENOBLE | NANTES | SOPHIA-ANTIPOLIS